

BIDS AND AWARDS COMMITTEE
BID BULLETIN No. 1

**Procurement for the General Cleaning and Repair of Two Air Conditioning Units
at Server Room of PHILGUARANTEE Office at BDO Tower
(PGC-BAC-2021-143)**

This is to inform all interested parties of the queries made by two (2) of the prospective bidders with regards to the above procurement.

QUESTION:

1. What is the rated HP of the two (2) Air Conditioning (AC) Units subject of the bidding?
2. Are the AC units wall mounted, ceiling cassette, ceiling mounted or floor mounted?
3. What type/kind of materials are to be used for the repair?

RESPONSE:

- Question 1: Both are 2.5HP split type AC Units.
- Question 2: The AC Units are wall mounted and connected to a cooling tower.
- Question 3: All prospective bidders shall be responsible for the type/kind of materials to be used for the repair.



IAN A. BRIONES

Chairperson
Bids and Awards Committee

01 October 2021