



TERMS OF REFERENCE
REPLACEMENT OF CONTROL PANEL FOR COOLING WATER PUMP SERVICING 2
UNITS OF WATER-COOLED ACU AT BDO TOWERS OFFICE SERVER ROOM

I. Scope of works

- A. Replacement of Control Panel for cooling water pump (servicing 2 units of water cooled ACU)

Scope of Works:

1. Supply/Install 3phase magnetic contactor; Includes control panel box with push button switch;
2. Synchronization of two (2) water-cooled ACU compressor to cooling water pump; and
3. Testing/Commissioning.


- B. Provide the required parts and supplies for the above scope of works

II. Terms of Delivery: 15 calendar days upon receipt of Job Order


III. Terms of Payment: 30 calendar days after completion

IV. Approved Budget for the Contract: The Approved Budget for the Contract is **Fifty-Six Thousand Seven Hundred Fifty Pesos only (₱ 56, 750.00)**, inclusive of all applicable taxes, chargeable against the Corporate Operating Budget for CY 2022.

Prepared by:


ARTURO E. BARRIOS
Administrative Officer III
Facilities and Maintenance Division

Reviewed by:


MARVYN ANTHONY C. GALANG
Administrative Officer V
Facilities and Maintenance Division

Approved by:


ROSEMARIE N. PRINCIPE
Vice President
Facilities and General Services Department